



**MUNICIPAL CORPORATION CHANDIGARH**  
Public Health Laboratory at Water Works Sector 39.

**TEST - REPORT**

Not for legal use

Ref. No. & Date : - No. SS/1728/22-23 Dated 17.05.2022

Issued to : - ☒ The Principal,  
Sharda Sarvhitkari Model Sr. Sec. School  
Sector 40-D Chandigarh.

Quantity of sample : - Approximate 1200 ml.

Date of Collection : - 19.05.2022

Client reference : - Sample collected by Laboratory Staff

Packing of sample : - Sample filled in P.P. and Glass Bottle.


Source of sample : - from School Tap of Sharda Sarvhitkari Model Sr. Sec. School Sector 40-D Chandigarh.


S. No.	Examination	Quality Standard	Units	Results
1.	Turbidity	<1.0	N.T.U	0.8
2.	pH	7.0-8.5	----	7.78
3.	Residual Chlorine	0.2 - 0.4	mg/L	0.2
4.	Total Alkalinity (as CaCO <sub>3</sub> )	200	-do-	84
5.	Total Hardness (as CaCO <sub>3</sub> )	200	-do-	70
6.	Chlorides (as Cl)	200	-do-	04
7.	Free & Saline Ammonia	Nil	-do-	Nil
8.	Total Dissolved Solids	500	-do-	130
9.	M.P.N. of Coliform Bacilli per 100ml of water	Zero	M.P.N.	0 (Excellent)

Payment received vide Receipt No.05/2022-23/075459, dated 18.05.2022, Amount Rs.3300/-.

**Note:- Water is fit for drinking.**

Lab. No. MCPHL/22/ 2149  
Dated: - 23.05.2022

  
Chemist,  
MCPH Laboratory,  
Chandigarh


  
Sub Divisional Engineer,  
M.C.P.H. Sub Division No. 2,  
Chandigarh

Endst No. MCPHL/22/ \_\_\_\_\_

Dated \_\_\_\_\_

Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector-17, Chandigarh for information please.

Sd/-  
Chemist  
MCPH Laboratory  
Chandigarh

Sd/-   
Sub Divisional Engineer,  
M.C.P.H. Sub Division No. 2,  
Chandigarh

